



**THE ADMINISTRATION OF UNION TERRITORY OF LADAKH**  
**FIRE AND EMERGENCY HEADQUARTERS UNION TERRITORY OF LADAKH**

(e-mail-soto-igp@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - F&ES/SP/NOC/2023-2290-9

Dated: - 14/06/2023

**Subject: Fire NOC of Govt. High School Apattee, Kargil.**

The report has been submitted by Divisional Fire Officer, Ladakh regarding the inspection of the school building. The detailed report of School Building is as under:

**Location/ Accessibility:**

The school building is constructed at Apattee, Kargil. It is located at Longitude 76.2083 and Latitude 34.5668. The site is approximately 17.4 Kms away from Fire and Emergency Services Station, Kargil. It takes approximately 01 hours to reach the site and is approachable for fire appliances.

**Detail of building:**

The school building has two blocks. The details of the blocks are as under.


**1<sup>st</sup> Block:** It is single storied building having four class rooms. There are two windows in each room and the size is 3x4 ft. All the windows have provision to open.

**2<sup>nd</sup> Block:** It is single storied building having principal office, computer lab, laboratory, smart class room and 05 numbers of class rooms.

**The following Fire Safety equipment which are installed in School Building:**

- 01.02 number of fire extinguisher ABC Type 6 kg capacity is installed in the school building.
- 02.04 numbers of sand bucket are installed in the school premises.
- 03.02 number of plastic tanks 1000 liters capacity are installed in the school premises.
- 04.01 submersible bores water pump is installed in the school premises.

**FIRE NOC is given in the favour Govt. High School Apattee, Kargil for the period of One year from the issuance.**

  
Superintendent of Police,  
Fire and Emergency Services,  
UT Ladakh.

**Copy to:**

1. Headmaster Govt. High School Apattee for information.
2. Divisional Fire Officers, Ladakh for information.
3. Office file.