



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail: igp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2021-447-448

Dated:- 11/1/2022

Subject: Fire NOC in favour of Govt. Higher Secondary School Chuchot Shamma, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the instant school which has been done by I/C Fire and Emergency Services, Leh. The detailed report is as under:

Location/ Accessibility:

The School is constructed at Chuchot Shamma, Leh. It is located at latitude 34.056245 and longitude 77.618036. The site is approximately 13 Kms away from Fire and Emergency Services Station, Leh. It takes approximately 20 minutes to reach the site which is approachable for fire appliances.

Detail of building:

The school building have 06 blocks and the detail of the block are as under:

1st block: It is single storied building having Principal office, staff room, examination hall, kitchen and sports room. There are two windows in each room and the size is 4x5 feet. Two sides of the window have provision to open.

2nd block: It is single storied building having store room. There are 04 windows and the size is 2x4 feet. Two windows have provision to open

3rd block: It is two storied building having one stair case. In the ground floor there are kitchen, staff room, NCC room and library. There are 3 windows in staff room, size is 6x5 feet and two windows in each room and the size is 7x5 feet. Two sides of the window have provision to open. 1st floor have ICT room, tourism room and 6 no's of class rooms.

4th block It is single storied building having 2 no's of laboratory and one class room. There are two windows in each room and the size is 6x5 feet and 7x5 feet. Two sides of window have provision to open.

5th block: It is single storied building having solar power bank. There are two windows and the size is 2x4 feet and 7x8 feet. One side of window have provision to open.

6th block: It is single storied building having chowkidar residence. There are two windows and the size is 5x5 feet. Two sides of the window have provision to open.

There are 120 students and 35 staffs.

The following Fire Safety equipment's found installed in School Building:

01. 12 no's of fire extinguishers ABC Type 4 kg capacity found installed in the school building.
02. 07 no's of sand buckets appropriately placed in the school premises.
03. 02 no's of plastic water tanks 1000 litres capacity and 3 no's of 500 litres capacity appropriately placed in the school premises.
04. 01 submersible bore connected with high rated pump appropriately placed in the school premises.

There is a mandatory requirement for keeping 2 exit stair cases in third block of the school building each having at least 1.5 meter width besides constructing 20 thousand litres of underground water tank in school premises.

A **provisional FIRE NOC for a period of 6 months** is given to **Govt. Higher Secondary School Chuchot Shamma, Leh** from the date of issuance of this letter and the school management is advised to fulfilling the above listed fire safety requirements in shortest possible time.

[Handwritten signature]
11/01/22

**Director, F&ES, Ladakh
PHQ, Agaling, Leh**

Copy to:

1. Principal, Govt. Higher Secondary School Chuchot Shamma, Leh for info
2. Superintendent of Police, F&ES, Ladakh for information and n/a